



Engineering, Planning and Zoning
City Hall, 125 East 6th Street
Marysville, Ohio 43040-1641
(937) 642-6015
FAX (937) 642-6045
www.marysvilleohio.org

September 2, 2010

Ms. Jenny Snapp
Logan-Union-Champaign Regional Planning Commission
P.O. Box 219
East Liberty, OH 43319

**Subject: Jerome Village – Glacier Park Neighborhood, Section 2 -AMENDED
Preliminary Plan and Plat Comments**

The City of Marysville previously submitted comments regarding the Preliminary Plan and Plat submittal for the Jerome Village – Glacier Park Neighborhood, Section 2 development. The following comments were not addressed in the amended preliminary plan and shall be addressed in the final engineering plans for this project.

General Comments:

1. Provide the water service for each residential lot near each property line.

Detailed Composite Utility Plan (Sheet 6):

1. The waterline diameter along Hawthorne Drive from Ryan Parkway to Cottonwood Drive shall be changed from 8" to 12".
2. The waterline diameter along Cottonwood Drive from Hawthorne Drive to Wells Road shall be changed from 8" to 12".

Detailed Composite Utility Plan (Sheet 7):

1. The waterline diameter along Hawthorne Drive from Ryan Parkway to Cottonwood Drive shall be changed from 8" to 12".

Please contact us if you need additional clarification or wish to discuss these comments further.

Sincerely,

Jeremy V. Hoyt, P.E.
Assistant City Engineer