



Engineering, Planning and Zoning  
City Hall, 125 East 6<sup>th</sup> Street  
Marysville, Ohio 43040-1641  
(937) 642-6015  
FAX (937) 642-6045  
[www.marysvilleohio.org](http://www.marysvilleohio.org)

---

September 2, 2010

Ms. Jenny Snapp  
Logan-Union-Champaign Regional Planning Commission  
P.O. Box 219  
East Liberty, OH 43319

**Subject: Jerome Village – Glacier Park Neighborhood, Section 6  
Preliminary Plan and Plat Comments**

The City of Marysville has the following comments pertaining to the water system design shown within the Preliminary Plan and Plat submittal for the Jerome Village – Glacier Park Neighborhood, Section 6 development.

**General Comments:**

1. Provide the water service for each residential lot near each property line to ensure the corporation stop location is away from the future driveway.
2. The primary waterline through this portion of the development (and along Brock Road) may be revised due to a conceptual Master Utility Layout change.

Please contact us if you need additional clarification or wish to discuss these comments further.

Sincerely,

Jeremy V. Hoyt, P.E.  
Assistant City Engineer