



Union Rural Electric Cooperative, Inc. | 15461 US Highway 36 Marysville, OH 43040
office: 800.642.1826 or 937.642.1826 | email: services@ure.com | website: ure.com

October 28, 2025

Bradley Bodenmiller
LUC Regional Planning Commission
10820 St. Rt. 347, PO Box 219
East Liberty, OH 43319

Name of Development – Lark Ravine

Details -

Number of Lots: 23

Front Setback: 25 Feet

Side Setback: Not Listed

Rear Setback: Not Listed

Placement of electric facilities – To be determined by final site layout, currently planning for front lot due to rear lot slope.

Union Rural Electric Terms and Conditions - Development must comply with URE's Terms and Conditions for Supplying Electric Service.

Easement Requirements – URE has easement requirements of 20 feet for underground primary and secondary facilities.

- Actual location of electrical facilities can be located within a 10 feet easement if adjacent property has additional easements or right of way for ingress and egress totaling a minimum of 20 feet. When on a property line, require 10 ft easement on each of the adjacent properties. Developer to install creek/stream crossing (directional bore if applicable) 10 feet beyond stream protection easements (when applicable).
- Utility Easement for URE electric facilities will be joint use for phone, cable or other private communication entities (fiber).
- Allow Utility ingress and egress of open space as necessary for maintenance, repairs, replacement of electric facilities.
- Where practical, do not place the easement area over building setbacks, adjacent to is acceptable. URE does not want the primary conductor to be within five feet from the basement walls or building footers.
- Electric easements must be platted and shown on final plat plans as electric easements.
- No permanent or semi-permanent structures, fencing, plantings, etc. shall be permitted in the easement areas. Said easement rights shall include the right, without liability therefore to remove trees and landscaping, including lawns within and without said easement premises which may interfere with installation or maintenance of facilities.

Street Crossings and Adjacent Property Paths - Street crossing and adjacent property paths to be determined when facilities layout is completed.

Landscape Plans - Landscape Plans shall not interfere with URE utility easements or access to



Union Rural Electric Cooperative, Inc. | 15461 US Highway 36 Marysville, OH 43040
office: 800.642.1826 or 937.642.1826 | email: services@ure.com | website: ure.com

URE facilities and shall comply with any regulatory and/or NESC rules.

URE Contacts:

- Matt Zarnosky – V.P. Engineering and Operations - Office 937-645-9246 – Cell 716-510-6640
- Brent Ransome – Manager of Engineering – Office 937-645-9241
- Ed Peper – Engineer – Office 937-645-9240
- Ron McGlone – Engineer – Office 937-645-9263 – Cell 937-594-3787
- Beau Michael – Key Accounts – Office 937-645-9251 – Cell 937-537-0370


General Comments:

- Sheet 6 of 9: No Comments
 1. URE is planning to install electric service in the front lots of the buildings in this subdivision.
 2. Easements will be needed in the front lots of all 23 parcels.
 3. Ure will also need easements in the front of reserve A,B&C for service to the development
 - 4.

URE will still need to collaborate with the developer to complete the electrical facility layout.

Regards,

Brent Ransome
Manager of Engineering Services
Union Rural Electric Cooperative, Inc
15461 US Hwy 36
Marysville, Ohio 43040
Direct: (937) 645-9241



ALFEN C. CROCK AND LORI L. CROCK
PARCEL 1
1.66 AC. (DEED)

[illegible]

TWP OF JEROME, COUNTY OF UNION, STATE OF OHIO
 VIRGINIA MILITARY DISTRICT
 SURVEY NUMBER 7181
 PRELIMINARY PLAT
 FOR
LARK RAVINE
 COMPOSITE UTILITY PLAN

EMHT
Evans, Mechwart, Hambleton & Tiffin, Inc.
Engineers • Surveyors • Planners • Scientists
2500 New Albany Road, Columbus, OH 43224
Phone: 614.775.4300 Fax: 614.775.5667
emht.com

DATE
OCTOBER 21, 2025

SCALE
1" = 50'

JOIN NO.
2024-0565

SHEET
6/9